

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SDU/PHED/275 Dated: 16/07/2026
It is certified that an inspection team headed by Suhail A. Khan (A.E.E.)

(Name of Officers with designation) from Jal Shakti PHE S/D Uri PHED

inspected the Army Good Will School Uri

(Name & Address of the school) on 11.06.26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DWTL/BLA dated 13.06.26

of DIST. DIVISIONAL LAB. Baramulla (PHED Lab) certified that the

Army Good Will School Uri (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six months only (06).

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Suhail A. Khan
A.E.E.
PHED S/D Uri

To Principal
Army Good Will School Uri
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.

Principal
Army Goodwill School
Uri



Government of Jammu & Kashmir

KASHMIR PUBLIC HEALTH ENGINEERING

DEPARTMENT

PHYSICO-CHEMICAL AND BACTERIOLOGICAL WATER ANALYSIS REPORT

SAMPLE ANALYSIS AT DISTRICT HEADQUARTERS, JAMMU
THROUGH LABS (CARE)

Report issued to: Principal Army Good Will School Uri

Your Letter No.: AGSU/REQ/970 Dated 15.04.2026

Sample Description: -

Lab Reference No DWTL/BLA

Source: Nambia Nallah

Date of Collection: - 11/06/2026

Village/Panchayat/Block: Uri Baramulla

Date of Receipt: - 11/06/2026

Place of Collection: - Tape water in premises of school

Date of Examination: - 11/06/2026

Status: Treated water

TO 13/06/2026

Collected By: Bashir Ahmad Shah

R E P O R T


Report Valid for six Months only


S.No	Parameters	Units	Results	Permissible Limits	Max. Tolerance Limits
1	Total Alkalinity	mg/l	-	200	600
2	Chlorides(as Cl-)	mg/l	20	250	1000
3	Calcium	mg/l	32	75	200
4	Coli form	MPN	Absent	Not detected	Not detected
5	Fluorides(as F-)	mg/l	0.5	1	1.5
6	Total Hardness(as CaCO ₃)	mg/l	300	200	600
7	Total Iron	mg/l	0.0	0.3	1
8	Magnesium(as Mg)	mg/l	65.12	100	300
9	Nitrate	mg/l	8	45	45
10	pH at °C	-	7.20	6.5-8.5	8.5
11	Residual Chlorine	mg/l	0.00	0.2	1
12	Total Dissolved Solids	mg/l	638.1	500	2000
13	Turbidity	NTU	1.12	1	5
14	Taste & odour	-	Agreeable	Agreeable	Agreeable
15	Phosphate	mg/l	0.00	1	5
16	Conductivity	µs/cm	1075	1000	2000
17	Ammonia	mg/l	0.00	0.5	0.5

IMPRESSION:-

All the tested parameters are within permissible limits, water is safe for drinking after proper chlorination.

Lab Assistant


In charge Laboratory Uri


Principal
Army Goodwill School
Uri